



# Safety Instructions



1, 2, 3, 4, 5, 6, 7,  
9, 11, 12, 13, 14, 15,  
16, 17, 18, 19, 21, 22,  
23, 25, 28, 30, 31, 34,



Info Hotline

+49 (0) 5041 998 389






Mon.-Do. 7<sup>00</sup>-20<sup>00</sup>

Fr. 7<sup>00</sup>-17<sup>00</sup>

Paulmann Licht GmbH  
31832 Springe / Germany  
www.paulmann.com

Art.-Nr.:  
977.20  
977.25

(+MA 197)  
PDG 08/09



**Transfo Profi 200/250VA**

<input checked="" type="checkbox"/>		Safety Instructions Nr. 28a/b	Ta: -20...+50°C	
<input type="checkbox"/>		Safety Instructions Nr. 28a	200VA TC: +85°C 250VA TC: +90°C	

230V PRI

H05VV-F 2x1.5mm<sup>2</sup>  
 NYM 3x2.5mm<sup>2</sup>

12V SEC

min. 1.5mm<sup>2</sup> x 6  
or 2.5mm<sup>2</sup> x 4

